




Fire sprinkler systems: Reduce the risk of unexpected water damage




Property claims

Water damage is a significant source of property claims for commercial properties such as hotels, office buildings, shopping malls and retail structures.



25% of all property claims are due to water loss¹



Water causes over \$5B annually in property losses²

Help minimize unexpected water damage from your fire sprinkler system




Reduce risks

Inspection, testing and maintenance of fire sprinkler systems — along with adequate building heat — can help reduce the risk of future water damage.



What fire sprinkler best meets your needs?

Fire sprinkler systems are designed to push out water until they are manually shut off. Installing the appropriate fire sprinkler system for your building and usage can help alleviate potential water damage.




The wet pipe system

(most commonly used)

– Pipes are filled with water. Heat from a fire opens the sprinklers closest to the fire.

– Usually only one or two sprinklers open.³



The dry pipe system

(for areas subject to freezing temperatures)

– Pipes are filled with pressurized air or gas used to hold water back in a heated space. Heat from a fire opens the sprinkler closest to the fire, air escapes and the dry pipe valve opens to allow water flow.

– Usually more sprinklers open than with a wet pipe system.³




The deluge system

(for high-hazard environments that could have fast-spreading fires)

– Pipes are not filled with water or gas as all sprinklers are open. A signal from a fire detection device opens the deluge valve.

– Water will flow from all sprinklers.³



The pre-action system

(for areas where concerns of water damage to property or equipment are high)

– Pipes are filled with pressurized air or gas. Loss of air or gas pressure summons maintenance. A signal from a fire detection device opens the pre-action valve, filling the pipes with water. Because sprinkler heads are closed, heat from a fire opens the sprinklers closest to the fire.

– Usually only one or two sprinklers open (similar to the wet pipe system). However, “double interlock” pre-action systems use more air or gas pressure in the pipes, delaying the water delivery and allowing more sprinklers to open at a time (similar to dry pipe systems).³

What causes water to escape?



Freezing of water-filled pipes



Mechanical damage



Installation defects



Deliberate sabotage



Overheating from excessive temperature near sprinklers



Corrosion of sprinklers, fittings, pipe, hangers and components



Environmental stress cracking of CPVC plastic sprinkler pipe and fittings



Manufacturing defects, including recalled sprinklers

What are the potential risks of water damage?



Damage

Destruction to property – contents, interior finishes and utility systems

Disruption

Loss of building use during repairs – interruption of business income and/or rental income



Health effects

Possible development of mold

Reputation

Lost customers or tenants due to the interruption

Costs

Repair or replacement of fire sprinkler system



Fire Sprinkler considerations



Maintain fire sprinkler systems in accordance with recognized standards

– Such as NFPA 25 available at www.NFPA.org

Ensure installations are completed by experienced and licensed contractors



Take action to reduce the chance of fire sprinkler system freeze-ups

Source:
1, 2 <http://www.amerestoration.com/water-damage/>
3 <http://www.incontrolfp.com/systems/>

Zurich
1400 American Lane, Schaumburg, Illinois 60196-1056
800.382.2150 www.zurichna.com

The information in this publication was compiled from sources believed to be reliable for informational purposes only. All sample policies and procedures herein should serve as a guideline, which you can use to create your own policies and procedures. We trust that you will customize these samples to reflect your own operations and believe that these samples may serve as a helpful platform for this endeavor. Any and all information contained herein is not intended to constitute advice (particularly not legal advice). Accordingly, persons requiring advice should consult independent advisors when developing programs and policies. We do not guarantee the accuracy of this information or any results and further assume no liability in connection with this publication and sample policies and procedures, including any information, methods or safety suggestions contained herein. We undertake no obligation to publicly update or revise any of this information, whether to reflect new information, future developments, events or circumstances or otherwise. Moreover, Zurich reminds you that this cannot be assumed to contain every acceptable safety and compliance procedure or that additional procedures might not be appropriate under the circumstances. The subject matter of this publication is not tied to any specific insurance product nor will adopting these policies and procedures ensure coverage under any insurance policy.

© 2016 Zurich American Insurance Company